

## LABORATORY REPORT

Prepared For: Water Treatment Operators  
14615 N. Fountain Hills Blvd.  
Fountain Hills, AZ 85268  
Attention: Joe Fiano

Project: Saguaro View Mgmt Co.

Sampled: 03/25/11  
Received: 03/26/11  
Issued: 04/01/11 15:03

NELAP #01109CA Arizona DHS#AZ0728

*The results listed within this Laboratory Report pertain only to the samples tested in the laboratory. The analyses contained in this report were performed in accordance with the applicable certifications as noted. All soil samples are reported on a wet weight basis unless otherwise noted in the report. This Laboratory Report is confidential and is intended for the sole use of TestAmerica and its client. This report shall not be reproduced, except in full, without written permission from TestAmerica. The Chain(s) of Custody, 3 pages, are included and are an integral part of this report.  
This entire report was reviewed and approved for release.*

### CASE NARRATIVE

#### LABORATORY ID

PUC1715-01  
PUC1715-02  
PUC1715-03

#### CLIENT ID

Well Depth = 547 Ft (1A)  
Well Depth = 505 Ft (1B)  
Well Depth = 463 Ft (1C)

#### MATRIX

Drinking Water  
Drinking Water  
Drinking Water

**SAMPLE RECEIPT:** Samples were received intact, at 3°C, on ice and with chain of custody documentation.

**HOLDING TIMES:** All samples were analyzed within prescribed holding times and/or in accordance with the TestAmerica Sample Acceptance Policy unless otherwise noted in the report.


**PRESERVATION:** Samples requiring preservation were verified prior to sample analysis.

**QA/QC CRITERIA:** All analyses met method criteria, except as noted in the report with data qualifiers.

**COMMENTS:** No significant observations were made.

**SUBCONTRACTED:** No analyses were subcontracted to an outside laboratory.

Reviewed By:



**TestAmerica Phoenix**

Suzanne Glass  
Project Manager

Water Treatment Operators  
14615 N. Fountain Hills Blvd.  
Fountain Hills, AZ 85268  
Attention: Joe Fiano

Project ID: Saguario View Mgmt

Report Number: PUC1715

Sampled: 03/25/11  
Received: 03/26/11

**SATISFACTORY**

## TOTAL METALS BY ICP/MS

Analyte	Method	Batch	Reporting Limit	Sample Result	Dilution Factor	Date Extracted	Date Analyzed	Data Qualifiers
<b>Sample ID: PUC1715-01 (Well Depth = 547 Ft (1A) - Drinking Water)</b>								
Reporting Units: mg/l								
Arsenic	E200.8	11C1043	0.0010	0.0089	1	3/28/2011	3/30/2011	
<b>Sample ID: PUC1715-02 (Well Depth = 505 Ft (1B) - Drinking Water)</b>								
Reporting Units: mg/l								
Arsenic	E200.8	11C1043	0.0010	0.0089	1	3/28/2011	3/30/2011	
<b>Sample ID: PUC1715-03 (Well Depth = 463 Ft (1C) - Drinking Water)</b>								
Reporting Units: mg/l								
Arsenic	E200.8	11C1043	0.0010	0.0088	1	3/28/2011	3/30/2011	

TestAmerica Phoenix

Suzanne Glass  
Project Manager

Water Treatment Operators  
14615 N. Fountain Hills Blvd.  
Fountain Hills, AZ 85268  
Attention: Joe Fiano

Project ID: Saguaro Valley Mgmt Co

Report Number: PUC1715

Sampled: 03/25/11  
Received: 03/26/11

**SATISFACTORY**

## INORGANICS

Analyte	Method	Batch	Reporting Limit	Sample Result	Dilution Factor	Date Extracted	Date Analyzed	Data Qualifiers
<b>Sample ID: PUC1715-01 (Well Depth = 547 Ft (1A) - Drinking Water)</b>								
Reporting Units: mg/l								
Fluoride	EPA 300.0	11C1007	0.40	0.70	1	3/26/2011	3/26/2011	
Nitrate-N	EPA 300.0	11C1007	0.20	0.78	1	3/26/2011	3/26/2011	
<b>Sample ID: PUC1715-02 (Well Depth = 505 Ft (1B) - Drinking Water)</b>								
Reporting Units: mg/l								
Fluoride	EPA 300.0	11C1007	0.40	0.62	1	3/26/2011	3/26/2011	
Nitrate-N	EPA 300.0	11C1007	0.20	0.78	1	3/26/2011	3/26/2011	
<b>Sample ID: PUC1715-03 (Well Depth = 463 Ft (1C) - Drinking Water)</b>								
Reporting Units: mg/l								
Fluoride	EPA 300.0	11C1007	0.40	0.60	1	3/26/2011	3/26/2011	
Nitrate-N	EPA 300.0	11C1007	0.20	0.78	1	3/26/2011	3/26/2011	

TestAmerica Phoenix

Suzanne Glass  
Project Manager